

c/77

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/ 430

Dated: 22/07/2024

To

The Addl. Commissioner of Police,  
Licensing Unit 1st Floor,  
P.S Defence Colony,  
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in r/o M/S Wahi Guest House Located at Ground, 1<sup>st</sup> & 2<sup>nd</sup> floors Plot No.6/82, WEA Padam Singh Road, Karol Bagh, New Delhi - 110005.**

Sir,

Please refer to online application No. 2024051107374, dated 21/06/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 15/07/2024 in the presence of Sh. Gun Bhadur Singh from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire Check Doors found not provided.
2. CO detectors found not provided.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully

(Atul Garg)  
Director  
Delhi Fire Service

Copy to: - The Manager, M/S Wahi Guest House Located at Ground, 1<sup>st</sup> & 2<sup>nd</sup> floors Plot No.6/82, WEA Padam Singh Road, Karol Bagh, New Delhi - 110005.