

c/64

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/ 440

Dated: 26/07 /2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Amreena Guest House located at 953, Gali Shyam Lal, Bazar Matia Mahal, Jama Masjid, Delhi.

Sir,

This has reference to online application I.D. no. 2024071010784 dated 10.07.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned of this department on 19.07.2024 in the presence of Mohd. Kifiatulla Khan (Manager) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. Hose reel hose provided but not functional.
2. CO detectors with panel and alarm system provided but not functional.
3. Fire pump not in auto start mode.
4. Exit signages not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Atul Garg)
Director

Delhi Fire Service

Tel: 011-23414000

2/6/24
19/7/24

Copy to:-

The Licensee,

M/s Amreena Guest House at 953, Gali Shyam Lal, Bazar Matia Mahal, Jama Masjid, Delhi.