

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/WZ/2024/ 426

Dated: 30/07/2024

To,

The Owner/Occupier,
M/s. Galaxy Automobile Pvt. Ltd.,
69/1 A, Moti Nagar, Najafgarh Road,
Industrial Area, New Delhi-110015.

Subject: - Fire Safety certificate in respect of M/s Galaxy Toyota (A unit of Galaxy Automobile Pvt. Ltd.), 69/1, Moti Nagar, Najafgarh Road, Industrial Area, Moti Nagar, New Delhi-110015.

Sir,

Please refer to your Email dated: - 30/03/2024 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officers concerned of this department on 13/05/2024 in the presence of Sh. Rakesh Kumar to see the functioning of fire safety equipments provided in the Building.

During inspection, it has been observed that the premises/building is running at Basement + Ground + one upper floor in a building comprised of Basement + Ground + 01 Upper floors. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Internal Hydrant, Yard Hydrant, Pumping arrangements & water storage tank etc provided. However the following shortcomings were observed.

1. Wired Glass smoke check door found removed.
2. First Aid hose reels are provided but not functional.
3. Detectors are provided in office area but not functional.
4. Sprinklers system are provided but not functional.
5. MOEFA is provided but not functional.
6. Internal Hydrants are provided but not functional.
7. Main pump capacity of 2 x 2850lpm & standby pump capacity of 2850lpm is provided but not functional.
8. Over head water storage tank capacity of 15,000 ltrs is found empty.

In view of above Shortcomings the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)
Director

Copy to: -

1. The Executive Engineer – I (Bldg.) HQ, NDMC, 9th floor Civic Centre, Minto Road, New Delhi – 110002.
2. The Dy. Director (Bldg.), DDA, INA, Vikas Sadan, New Delhi.

29/7/2024