

c/19

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2024/ School / 480

Dated: 30/07/2024

To,

The Principal,  
G.D Goenka La Petite (Durga Education Society)  
Pocket - 03, Sector-17, Dwarka, New Delhi - 110075.

**Subject: Renewal of Fire Safety Certificate in r/o G.D Goenka La Petite (Durga Education Society) Located at Pocket - 03, Sector-17, Dwarka, New Delhi - 110075.**

Sir,

Please refer to your letter No. nil, dated 27/06/2024 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned of this department on 18/07/2024 in presence of Sh. Aditya Bansal (Owner) from fire safety point of view.

During the course of inspection following shortcomings are observed.

1. Hose reel hose & hydrants found nonfunctional.
2. PA system found nonfunctional.
3. Terrace fire pumps found nonfunctional and not in auto mode.
4. Exit signage's found removed at some places.
5. One room found erected at terrace.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation with this department for further consideration in the matter.

(Anil Garg)  
Director  
Delhi Fire Service

ok

Copy to; -

The, Directorate Of Education Old Secretariat Delhi - 110054.