

c/37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/ 489

Dated: 02/08/2024

To,

The Principal,
Govt. Co-ed. Secondary School
Sector - 16 A, Dwarka, New Delhi - 110078.

Subject: Renewal of Fire Safety Certificate in r/o Govt. Co-ed. Secondary School Located at Sector - 16 A, Dwarka, New Delhi - 110078. (School ID-1821242).

Sir,

Please refer to your letter No. Govt-Co-Ed/SSS/16A/90 dated 28/06/2024 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned of this department on 18/07/2024 in presence of Ms. Santara Kumari (Principal) from fire safety point of view.

During the course of inspection following shortcomings are observed.

1. Only one staircase of width 125 cm found provided in new block. The width of staircase must be increased to 1.5m or an additional staircase of 1m clear width must be provided up to terrace level.
2. Fire extinguishers not provided in new block and found removed in old block.
3. Exit signage's not provided/ removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation with this department for further consideration in the matter.

(Atul Garg)
Director
Delhi Fire Service

Copy to; -

1. The, Directorate Of Education Old Secretariat Delhi - 110054