

0/100

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/2024/ 483

Dated: 30 /07/2024

To

The Head of School,
Govt. Lady Noyce Sr. Sec. Special School (Co-Ed),
For the Hearing Impaired, Firoz Shah Kotla,
Delhi Gate, New Delhi.

**Sub: Regarding issuance of FSC in r/o Govt. Lady Noyce Sr. Sec. Special School (Co-Ed),
For the Hearing Impaired, Firoz Shah Kotla, Delhi Gate, New Delhi.**

Sir,

This has reference to your letter no. GLNS/2024/152 dated 20/06/2024, on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 17.07.2024 in the presence of Sh. Love Gupta, PRT and the following shortcomings were observed.

1. First hose reel is not provided in the building.
2. Pumps of 450 LPM and Over head tank of 10,000L liter capacity is not provided.
3. Alternate staircase found closed and not available to the students.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully,


(Anil Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.