



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/SGH/2024/SZ/ 427

Dated: 30/07/2024

To

The Administrative Officer,
O/o The Resident Commissioner,
Gujarat Bhawan, Plot No. 11, Kautilya Marg,
Chanakya Puri, New Delhi-110021

Sub: Regarding issuance of Fire NOC of "Gujarat Bhawan" at Plot No. 13, Kautilya Marg, Chanakya Puri, New Delhi-110021

Sir,

This has reference to your letter received through outdoor diary No. 3749 dated 04/07/2024. In this connection, the said premise was visited by the officers concerned of this department on dated 15/07/2024 in the presence of Sh. Mohtashim Lahri (AE/Elect.) to verify the compliance of shortcomings communicated vide this office letter No. F.6/DFS/MS/SGH/SZ/2020/2142 dated 26/08/2020 and observed no progress towards rectification of the same. In addition, some more shortcomings have been observed, thus, the shortcomings are as below.

1. Fire Check Door found removed at some places.
2. Smoke management system in basement found removed and not provided in upper floors.
3. First Aid hose-reel found non-functional.
4. MOEFA system found non-functional and removed from some of the places.
5. Public Address system found not provided.
6. One of the fire pumps found non-functional and other not on auto mode.
7. Terrace level fire pump found non-functional.
8. Exit signages found removed at some places.

In view of the above shortcomings, the application for issuance of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL KARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Chief Architect, Department of Architecture & Enviorms, N.D.M.C. Palika Kendra, New Delhi-110001