



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/GH/2024/ 454

Dated 30/07/2024

To

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: -Regarding renewal of fire safety certificate in r/o M/s Hotel New City located at A-7, G T K Road, Adarsh Nagar, Delhi-110033.

Sir,

This has reference to your online MHA Portal I'd No.2024070110189 dated 01.07.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 13.07.2024 in the presence of Sh. Rizwan to verify the fire safety arrangements as stipulated in NBC Part 4. During the course of inspection it was observed that the building premise is comprised of basement, ground & 02 upper floors (but guest house running at second floor only). Your request for FSC is rejected under Rule 36 (3) due to following shortcomings.

1. The iron staircase width of 1.25m from ground to 2nd floor found removed at site.
2. Fire check door found removed in staircase and service rooms.
3. Hose reel hose provided but not functional.
4. Carbon monoxide detector & panel found removed in guest house.
5. MOEFA system provided but not functional.
6. Terrace level fire pump capacity of 450lpm found removed at site.
7. Terrace level fire water tank capacity of 5,000ltrs found removed at site.
8. Exits & floors signage's found removed.
9. Standby power supply found removed.

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)
Director

Ph: 011-23414000

29/7