

DFA
FT

C-3



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/ CC / 220

Dated: 03/08/2024

To

Sh. Sardar Gurdeep Singh (Owner)
Plot No-289, GF & FF, Dhaka Johar,
Delhi-110009.

Sub: - Inspection report in r/o M/s KGS & Vision IAS Coaching Centre at Plot No-289, Ground & first floor, Dhaka Johar, Delhi-110009.

Sir,

With reference to the Hon'ble High Court of Delhi order dated 10.05.2024 in the case no- W.P.(C) 8534/2023 & Ors in the matter of Court On Its Own Motion VS Govt. of NCT of Delhi, it is informed that the aforesaid coaching centre was inspected by the Delhi Fire Service/MCD (JTF) officers concerned on dated 28.05.2024.

During inspection it was observed that the above building is comprised of ground & 03 upper floors and coaching centre is running at ground & first floor only, 2nd floor- sealed by MCD, 3rd floor- residence. **As per order of Hon'ble High Court of Delhi dated 10.05.2024 Sl. No- 08 the coaching centre must obtain Fire Safety Certificate from Delhi Fire Service.** However, following shortcomings were observed at the time of inspection:-

1. There is 02nos of staircase is provided having width of 1.05m each against the requirement of 1.50m each from ground to terrace level.
2. The width of classroom doors is 1.0m & 1.10m against the requirement of 1.20m each.
3. Hose reel hose is provided but not functional.
4. Terrace level fire pumps capacity 450lpm is provided but not functional.
5. Terrace level fire water tank capacity of 5,000ltr is provided against the requirement of 10, 000ltr.
6. Exit signage's is not provided at strategic location in the building.
7. Standby power supply is not provided.
8. Electrical meter installed in staircase wall needs to be removed.

You are requested to submit sanctioned building plan or as built plan duly signed by registered architect and owner of the above building and rectify above mentioned shortcomings under intimation to this department within 30 days from the date of issuance of this letter failing which action will be initiated as per Delhi fire Service Act 2007 & Rules 2010, till such time the coaching centre shall not be allowed to operate & management will be held responsible for loss of life & property.

Yours faithfully

(Atul Gang)

Director

Ph: 011-23414000

Copy to:-

1. The Executive Engineer (Bldg.)-I, Rajpura Road, Civil Line Zone, Delhi.

25/8