

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2024/SZ/ 494  
To

Dated: 02.08./2024

The Principal,  
Jose Marti Sarvodaya Vidyalaya,  
R. K Puram, Sector 12,  
New Delhi - 110022

Sub.- Renewal of Fire Safety Certificate in r/o M/s Jose Marti Sarvodaya Vidyalaya, R. K Puram, Sector 12, New Delhi - 110022.

Sir,

This has reference to your Email dated 18/07/2024 on the subject cited above. In this connection, the said school premises have been inspected by concerned nominated of this department on 26/07/2024 in the presence of Mr. Dharmender Singh (Principal). During the inspection it was observed that school is comprised of Ground plus two upper floors, Except Auditorium. The shortcomings observed are as below.

1. First Aid Hose Reels provided but found not working.
2. Terrace level pump capacity 450 LPM provided but found not working.
3. Overhead tank capacity 10,000 ltrs found empty.
4. Exit signage found removed.

In view of above shortcomings, renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcoming under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054