GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 452

Dated: -39/97-/2024

To,

The Manager, M/S Krishna Plaza Guest House Plot No. 1, Block 80-A, Krishna Market, Main Bazar, Pahar Ganj, New Delhi.

Sub: Regarding renewal of FSC in r/o M/S Krishna Plaza Guest House located at Plot No. 1, Block 80-A, Krishna Market, Main Bazar, PaharGanj, New Delhi.

Sir,

This has reference to your online ID No. 2024070910719 dated 10/07/24, on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 20/07/24 in presence of Manager and following shortcomings were observed:

- 1. Fire Check door are not provided as per gazette notification 27.05.2019.
- 2. CO detectors are not provided as per gazette notification 27.05.2019.

Hence, the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter

Yours faithfully,

DIRECTOR Delhi Fire Service

213

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.