

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/SZ/2024/ School | 479

Dated: 30/07/2024

To,

The Principal,  
Manav Sthali Global School  
Double Storey, New Rajinder Nagar,  
New Delhi - 110060.

**Subject: Renewal of Fire Safety Certificate in r/o Manav Sthali Global School Located at Double Storey, New Rajinder Nagar, New Delhi - 110060.**

Sir,

Please refer to your letter No. MSGS/DS/2024 date 21/06/2024 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned of this department on 23/07/2024 in presence of Ms. Harleen Kaur (Employee) from fire safety point of view.

During the course of inspection following shortcomings are observed.

1. Hose reel hose found nonfunctional & damaged at terrace.
2. MOEFA found nonfunctional at second floor.
3. Terrace fire pumps found nonfunctional on auto mode.
4. Overhead fire water tank of capacity 10000 ltrs. found empty.
5. Exit signage's found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation with this department for further consideration in the matter.

(Atul Garg)  
Director  
Delhi Fire Service

Copy to; -

The, Directorate of Education Old Secretariat Delhi - 110054.