

c/38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 485

Dated: 30/07/2024

To,

The Manager,
Rao Brij Mohan Public School,
Plot No.-7, Brij Vihar, Paprawat, New Delhi-110043.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Rao Brij Mohan Public School, Plot No.-7, Brij Vihar, Paprawat, New Delhi-110043.

Sir,

Please refer to your letter No. RBMPS/2024/019, dated 05.07.2024, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on dated 22.07.2024 in the presence of Mrs. Anita Yadav (Manager), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school building comprised of ground floor plus two upper floors, and have following shortcomings: -

1. Hose reel found provided but not functional.
2. Terrace fire pump 450 LPM found provided but not functional.
3. Overhead water storage tank capacity of 3,000 ltrs found provided against requirement capacity of 10,000 ltrs.
4. Exit signage's are found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service
07/07/24

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.