

CS6



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 481

Dated: 30/07/2024

To,

The Principal,
Sarvodaya Co-ed Vidyalaya No-1
At Shakti Nagar, Delhi-110007.

Sub:- Regarding renewal of fire safety certificate in r/o Sarvodaya Co-ed Vidyalaya No-1, (School ID No-1207037) located at Shakti Nagar, Delhi-110007.

Sir,

Please refer to your letter no- SV/CO-ED/SN1/2024/384 Dated 13.06.2024 received in this department vide outdoor dairy no-3246 dated 21.07.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 20.07.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 03 upper floors only. At the time of inspection Sh. Rakesh Kr. Sorot (Principal) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose provided but not functional and some nozzles found missing.
2. Terrace level fire pump capacity of 450lpm each provided but found not functional.
3. Exit and floor signage's found removed at strategic locations in the school building.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Deputy Director of Education, Zone-VII, District North Lucknow Road, Timarpur, Delhi-110054.