

cl44

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 484

Dated: 30/07/2024

To,

The Manager,
Sarvodaya Kanya Vidyalaya,
Matiala, New Delhi-110059.

Sub: - Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Sarvodaya Kanya Vidyalaya at Matiala, New Delhi-110059.

Sir,

Please refer to your letter No. SKV/Matiala/2024/853 dated 20.06.2024, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on dated 22.07.2024 in the presence of Mrs. Chaudhary (Principal), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school having three blocks Main block ground plus three, Pry Block ground plus one & SPS Block ground plus three upper floors, and have following shortcomings: -

1. Corridor found blocked at 2nd floor level with Steel Almira.
2. Hose reel found provided but not functional.
3. Terrace fire pump 450 LPM found provided but not functional.
4. Exit signage's are found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter.

Yours faithfully


(Atul Garg)

Director

Delhi Fire Service



Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.