



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6 /DFS/MS/EH/SZ/2024/ 425

Dated: 30/07/2024

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defence Colony, New Delhi.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Savage Coffee Private Limited First Coffee located at Ground floor, Shop No. 16, Pacific Mall, CPD-48, Sarita Vihar, New Delhi-44.

Sir,

With reference to the MHA online application ID no. 2024070210325 on the subject cited above, it is informed that the said restaurant was inspected by a team of officers concerned from this department on 23.07.2024 in the presence of Mr. Ravi Gupta (Manager) and it was observed that the restaurant is running at Ground floor of the building which is comprised of Basement + Mezzanine + Ground + 5 upper floors. During the inspection following shortcomings were observed:

1. Width of both exit doors shall not be less than 1.50 meters each.
2. Hose reel found not provided.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director
Delhi Fire Service

DL
25/7/24