

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/Hospital/2024/SZ/429

Dated: 30/07/2024

To

Dr. Vishal Dutt Gour,
M/s SCI Health care Pvt Ltd
M-4, Greater Kailash-I,
New Delhi 110048.

Sub: Regarding issuance of FSC in r/o M/s SCI Health Care Pvt Ltd at M-4, Greater Kailash-I New Delhi 110048.

Sir,

This has reference to your letter no nil dated 03/07/2024 received through outdoor diary no 3819 dated 15/06/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 05.07.2024 in the presence of Mr. Hemant Kumar to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The Exit door width of patient room is 1.10 mtr & main exit doors width is 1.40 mtr against the required width of patient rooms is 1.25 mtr and main exit door width is 2.0 mtr each.
2. The width of corridor is 1.80 mtr against the required width of 2.40 mtr.
3. First floor OT floor alternative exit escape found closed.
4. Fire check door not provided.
5. Smoke management system in basement and upper floor not provided.
6. First aid hose reel provided but found nonfunctional.
7. Automatic sprinkler system provided but found nonfunctional.
8. Pumps are not on auto mode.
9. Additional construction of office space at terrace level is not allowed
10. There are deviations in existing building plans Vis a vis bldg plans approved by the building department. Hence, the management is here by advised, to refer two sets of re-vised building plans (current occupancy) including section/elevation/lay out plan on the scales as mentioned in UBBL 2016 duly marked with fire and life safety systems as per NBC part 4. (Through common application form (CAF)

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, F-17, Karkardooma Delhi 110032 for necessary action.