

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/SCHOOL/WZ/2024/ 490

Dated: 02/08/2024

To

The Principal,  
S.D.M.C Primary School,  
Vishal Enclave,  
New Delhi -110027.**Sub: - Inspection report in respect of S.D.M.C Primary School located at Vishal Enclave, New Delhi -110027.**

Sir,

Please refer to your Email dated 02/07/2024 on the subject cited above. In this connection, it is to inform you that the said building/premises was inspected by the officer concerned of this department on 23/07/2024 in presence of Smt. Sarwat Parveen (Principal) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above said school is comprised of Ground + Two Upper Floors. The following Shortcomings were observed.

1. First Aid Hose Reel is provided but not functional.
2. Main fire pump of capacity 450 lpm is provided but not function.

In view of above Shortcomings the application for renewal of Fire safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

  
(Atul Garg)  
Director

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.

1/2  
30/7/2024