

c/07

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2024/SZ/ 477

Dated: 30/07/2024

To,

The Principal,  
Vivekanand Model School,  
WZ-363, Guru Nanak Nagar,  
Tilak Nagar, New Delhi-110018.

**Sub: - Regarding issuance of FSC from fire safety point of view in r/o Vivekanand Model School locate at WZ-363, Guru Nanak Nagar, Tilak Nagar, New Delhi-110018.**

Sir,

Please refer to your letter No. Nil, dated 03.06.2024, received in this office outdoor dairy No. 2511 dated 06.06.2024, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on 12.07.2024 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Ms. Krishna Taneja (Principal) was present and it was observed that the building is comprised of ground floor plus one upper floor and have following shortcomings: -

1. One staircase of 0.90 m. found provided against requirement of one staircase with width of 1.50 m. if not provided an additional staircase should be provided with width of 0.75 m.

In view of above, issuance of FSC cannot be considered at this stage Therefore you are suggested to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

9/07/24

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.