

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2024/ 434

Dated: 05/08/2024

To,

The President,
Air India Employees CGHS Ltd
Plot No. 09, Sector-03, Dwarka,
New Delhi - 110075.

**Subject: Non – Compliance of Fire Safety Norms in r/o Air India Employees CGHS Ltd
Located at Plot No. 09, Sector-03, Dwarka, New Delhi – 110075**

Sir,

Please refer to your letter no AIECGHS/Fire Safety Cert/2024 dated 23/06/2024 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officer concerned from this department on 26/07/2024 in the presence of Sh. Jasbir Singh (Manager) for fire safety point of view.

During the course of inspection following shortcomings have been observed

1. Smoke exhaust system found nonfunctional in basement.
2. Only one fire extinguishers of ABC type 5Kg capacity is found provided against required two fire Extinguishers at each floor.
3. PA system found nonfunctional.
4. Exit signage found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Further the occupancy of the building premises without valid Fire Safety Certificate is on the risk and responsibility of the management committee

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The, Joint Director (Building), DDA, Vikas sadan, INA, New Delhi