

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

c/65

No.F6/DFS/MS/NDZ/2024/ E4 | 308

Dated:- 30/07/2024

To,

The Manager,  
M/S Desi Vibes Restaurant (A Unit of Goyal  
Kitchen and Grill Pvt. Ltd.), at N-95 and half  
portion of N-49, 2<sup>nd</sup> floor, N-Block,  
Connaught Place, New Delhi.

**Sub: Regarding issuance of FSC in r/o M/S Desi Vibes Restaurant (A Unit of Goyal Kitchen and Grill Pvt. Ltd.), at N-95 and half portion of N-49, 2<sup>nd</sup> floor, N-Block, Connaught Place, New Delhi.**

Sir,

This has reference to online ID No 2024051707743 dated 02/07/24, on the subject cited above In this connection it is to inform you that the site was inspected by the officers concerned department on 16/07/24 in the presence of **Manager** and following shortcomings were observed:-

1. Alternate exit found blocked.
2. Dry grass and bushes for interior decoration is required to be removed.

In view of above, the case is rejected with a request to rectify the above shortcomings for further consideration in the matter.

Yours faithfully

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.