

c/67

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2024/ 307

Dated:- 30/07/2024

To,

The Manager,
M/S Evergreen Land mark Pvt. Ltd.,
54 Ground Floor, Janpath,
Connaught Place, New Delhi.

Sub: Regarding issuance of FSC in r/o Evergreen Land mark Pvt. Ltd., at 54 Ground Floor, Janpath, Connaught Place, New Delhi

Sir,

This has reference to online ID No 2024070310348 dated 03/07/24, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 16/07/24 in the presence of Manager and following shortcomings were observed:-

1. Hose reel found nonfunctional as the hydrant line is disconnected.
2. Fire Pump found nonfunctional.

In view of above, the case is rejected with a request to rectify the above shortcomings for further consideration in the matter.

Yours faithfully

(Anil Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.