



To,

The President,
Police Housing Complex,
Mandoli Jail, Shahdara,
Delhi – 110093.

Subject: - Regarding grant of Fire Safety Certificate in r/o Police Housing Complex, Mandoli Jail, Shahdara, Delhi – 110093.

Sir,

This has a reference to your Outdoor Diary No. 4278 dated 18/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 25/07/2024 in the presence of Mr. Yash Pal (Head Constable), and observed that building comprised of 12 Blocks, Stilt plus ten upper floors (360 flats) only.

Following shortcomings were observed during time of inspection:

1. All fire extinguishers found empty.
2. First-Aid-Hose Reel provided but not functional.
3. MOEFA provided but not functional.
4. Public Address System provided but not functional.
5. Internal Hydrants provided but not functional.
6. Fire pump of 900 LPM provided but not functional.
7. All overhead tanks found empty.
8. Exit & floors Signage's not provided at strategic location in the building.
9. Standby power supply not provided.
10. All Co₂ flooding system found empty.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

o/c  DELHI FIRE SERVICE

Copy to: -

1. Dy. Commissioner of Delhi Police Head Quarters, 9th floor MSO building I.P Estate, New Delhi – 110002.
2. Mr. Yogender Kumar Sing (Inspector), Police Station Harsh Vihar, Mandoli Jail, Shadhara, Delhi – 110093.