

C/101



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2024/ 430

DATED: 31/07/2024

To,

The President / Secretary
Pragya C.G.H.S. Ltd.
Plot No-1-B, Sector-2, Dwarka,
New Delhi-110075.

Subject: - Renewal of Fire Safety Certificate in r/o Pragya C.G.H.S. Ltd. Located at Plot No-1-B, Sector-2, Dwarka, New Delhi-110075.

Sir,

Please refer to your email, dated-08/07/2024 on the subject cited above. In this connection it is to inform to you that the above said residential building has been re-inspected by the officer concerned of this department on 23/07/2024 in the presence of Sh. Rajesh Sharma (Manager) from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six meter wide internal road around the building found blocked/encroached.
2. Staircases found partially blocked & locked at terrace level.
3. Hose reel hose & hydrants found nonfunctional.
4. Terrace pump found nonfunctional & main valve found closed at terrace.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Further the occupancy of the building without valid Fire Safety Certificate is on the risk and responsibility of the management committee

Yours faithfully,

(Atul Garg)
(Director)

Delhi Fire Service

Copy to:-

1. The Joint Director (Building), DDA, Vikas Sadan, INA, New Delhi.

Ok

24/7/24