

c/05



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/2024/EH/ 311

Dated 30/07/2024

To

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Sarvasya (A Unit of Dockrell Hospitality LLP) located at Ground Floor, No-56, Orbit Plaza North Gate, Gujrawala Town, Part-I, Nagar, Delhi-110009.

Sir,

This has reference to online mha portal I'd. No. 2024070110190 dated: 01.07.2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 13.07.2024 in the presence of Mr. Yogesh (Attendant) to verify the fire safety measures installed in the building and observed that the building is comprised of ground & 02 upper floors but restaurant is proposed at ground floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 There are two exit doors having width of 2.10m & 75cm provided. The second exit door is also not qualifying the requirement of safe means of escape as this escape route is passing through the kitchen area of the restaurant.
- 2 Terrace level fire water tank capacity of 10,000ltrs is provided against the requirement of 20,000ltr.
- 3 Exits signage's is not provided at strategic location in the restaurant.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of restaurant is at your own risk & responsibility.

Yours faithfully


(Anu Garg)
Director

Ph: 011-23414000

G E