



No. F6/DFS/MS/Hospital/NDZ/2024/ 431

Dated: 31/07/2024

To,

The Director,  
M/s Signature Heart & Multi Specialty Hospital  
C - 2/41 A, Service Lane, Yamuna Vihar,  
North East Delhi – 110053.

**Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Signature Heart & Multi Specialty Hospital located at C - 2/41 A, Service Lane, Yamuna Vihar, North East Delhi – 110053.**

Sir,

This has a reference to your outdoor diary no. 3649 dated 01/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 08/07/2024 in the presence of Dr. Anju Gupta (Director)& Dr. Ashish Singhal and observed that building is comprised of basement, stilt + ground plus three upper floors.

1. The widths of both the staircases are less than the required width of 2.0 & 1.50 meter respectively.
2. Staircases are not segregated on ground floor
3. Fire check doors not provided.
4. The width of door size is 0.95 meter against the requirement of 1.25 meter.
5. Smoke Management System not provided in basement and upper floors.
6. First-Aid-Hose Reel provided but not functional.
7. Automatic Sprinkler System provided but not functional in basement and shall be provided in upper floors also.
8. Internal Hydrants provided but not functional.
9. Pumping arrangements one electric pump of 1620 LPM, one jockey pump of 180 LPM and one diesel pump of 1620 LPM not provided.
10. Overhead water storage tank capacity 5,000 liters is provided against requirement of 10,000 liters.
11. Exit&Floors Signage's not provided at strategic location in the building.
12. Lift lobby is required on each floor.
13. Lift Pressurization fans provided but not functional.
14. Lift signage's not provided.
15. Standby Power Supply not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Director, Signature Heart & Multi Specialty Hospital located at C-2/41 A, Service Lane, Yamuna Vihar, North East Delhi – 110053.
2. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3<sup>rd</sup> floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi – 110032.