GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001

No. F6/DFS/MS/MN/2024/ EH 305

Dated: 30 07 /2024

To,

The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. addlcp.lic-dl@nic.in

Subject: <u>Issuance of Fire Safety Certificate in respect M/s. Tikka Junction (Tikka Junction Pvt. Ltd.) Located at A-22 & A-23, First Floor, Basai Darapur, Tagore Market, Kirti Nagar, New Delhi - 110015.</u>

Sir,

Please refer to the online application Id No. 2024070710576 dated 08/07/2024 received through MHA portal on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 16/07/2024 in the presence of Sh. Nikhil Ajmani to check the fire safety arrangements provided in the building.

During inspection, it was observed that the said restaurant is running at First floor in a building comprised of Ground plus 2 upper floors. However the following shortcomings were observed.

- 1. Width of staircase is provided 1.5m x 2 against requirement of 2m & 1.5m.
- 2. Width of door size is provided 1.5m x 2 against requirement of 2m & 1.5m.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The Licensing authority /statutory authority may take suitable necessary action as deemed fit.

Yours Faithfully

(Atul Garg)

Director

Copy to: -

1. The Owner/Occupier M/s. Tikka Junction (Tikka Junction Pvt. Ltd.) Located at A-22 & A-23, First Floor, Basai Darapur, Tagore Market, Kirti Nagar, New Delhi - 110015.

2. The Dy. Health Officer, West Zone, South Delhi Municipal Corporation, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id:- (dhowest zone@gmail.com)