



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/10
आजादी का
अमृत महोत्सव

No. F6 /DFS/MS/EH/SZ/2024/ 312

Dated: 30/07/2024

To

The Joint Commissioner of Police,
Office of Joint commissioner of Police: Licensing,
1st Floor, P S Defence Colony, New Delhi.

Sub: -Regarding renewal of Fire Safety Certificate in r/o M/s Upgrade Kitchen & Bar (A Unit of Urban Gala), Shop No. 42, 43, 44, FF, India Mall, Community Centre, New Friends Colony, New Delhi-25.

Sir,

with reference to the Online application ID no. 2024071210900 on the subject cited above, it is informed that the said restaurant was inspected by a team of officers concerned from this department on 22.07.2024 in the presence of Mr. Chhabra (Owner) and it was observed that the restaurant is running at 1st floor of the India Mall building which is comprised of Basement + Ground + 4 upper floors. During the inspection following shortcomings were observed:

1. Hose reel found removed.
2. Internal hydrant system found non functional.
3. Fire pump having capacity 450 LPM & head 40 m found removed.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director
Delhi Fire Service

23/7/24