

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

Dated: 07/08/2024

No. F.6/DFS/MS/Hospital/2024/SZ/443
To

Dr. D.S Rajesh,
Room No 301, FHQ,
BSF No 11, CGO Complex,
Lodhi Road, New Delhi

Sub: Regarding issuance of FSC in r/o M/s 500 Bedded General & 300 Bedded Super Speciality Hospital at Maidan Garhi New Delhi (Central Armed Police Force institution of Medical Science (CAPFIMS)).

Sir,

This has reference to your online CPWD Fire NOC Approval System dated 18/07/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 30.07.2024 in the presence of Mr. Pranjal Shrivastava (Executive Engineer/Civil) & Mr. Anup Kumar (Executive Engineer/ Electrical) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. 09mtr / 06 mtr access road are not meeting at some points.
2. The Doors are not as per above schedule, please re-visit the schedule. The doors in wars shall open outward as advised during inspection.
3. Clarify basements are single or double under hospital blocks.
4. Shafts are not sealed.
5. Sprinkler needs to be extended at some points even in basements.
6. Dedicated system not provided in pump room.
7. Kitchen in basement not permitted.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE