



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/ 441

Dated: 07/08/2024

To

Sh. Sanjiv Gupta (Director)
M/s Agro freeze Cold Storage at
Plot No. 03, Indl. Area, Rajasthani
Udyog Nagar, G.T.K. Road, Delhi-33.

Sub: - Regarding renewal of fire safety certificate in r/o M/s Agro freeze Cold Storage located at Plot No. 03, Indl. Area, Rajasthani Udyog Nagar, G.T.K. Road, Delhi-110033.

Sir,

Please refer to your received through e-mail dated 29.07.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 03.08.2024 to check the existing fire safety measures. During inspection it has been observed that the premise is comprised of basement, ground & 02 upper floors. At the time of inspection Mr. Sarvesh Kumar (Plant Incharge) was also present at site. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings:-

1. Some fire check door found removed at ground floor in the building.
2. Internal hydrant is provided but not functional & damaged condition. Some hoses, branch & coupling found missing.
3. Terrace level fire pump capacity of 450lpm found non functional and in badly damaged condition. Auto starting found non functional.
4. Terrace level fire water tank capacity of 10,000ltr found empty.
5. Exit & floor signage's found removed at strategic locations in the building.
6. One back side staircase found blocked, Out of four stairs.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of cold storage building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Dy. Commissioner, Municipal Corporation of Delhi., Keshavpuram Zone, MCD, Delhi.