

C-32



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/Sol

Dated:07/08/2024

To

The Principal, Air Force Bal Bharti School, Lodhi Road, New Delhi–110003

Sub: Regarding renewal of Fire Safety Certificate in r/o Air Force Bal Bharti School, Lodhi Road, New Delhi-110003

Sir,

This has reference to your letter received through outdoor diary No.579 dated 12/04/2024, on the subject cited above. In this connection, the school premises was visited by the officer concerned of this department on 29/07/2024 in the presence of Dr. Sunil Sharma (Admin/UDC) to verify the status of the fire safety arrangements provided therein. During the inspection, the shortcomings observed are as below.

Senior Block:

1. Hose-reel hose found provided but non-functional.

2. Terrace level fire pump not on auto mode and found loose hanging wires beside the pump.

3. Pressure gauge near terrace pump found defective.

- 4. Ceiling height of continuous staircase to terrace is not in conformity with clause 4.2.11 of NBC Part 4.
- 5. Over-head captive water storage capacity 2000 liters provided against required 2500 liters.

Junior Block:

- 1. Fire extinguishers not provided at ground floor.
- 2. Hose-reel hose found provided but non-functional.
- 3. Terrace level fire pump was non-functional.
- 4. Pressure gauge near terrace pump found defective.

Multipurpose Hall:

1. Exit signage found removed.

Art & Science Block:

1. Fire extinguishers not provided in library.

2. Hose-reel hose found provided but non-functional.

3. Terrace level fire pump was non-functional.

4. Pressure gauge near terrace pump found defective.

In view of the above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUZ GARG) DIRECTOR

DELHI FIRE SERVICE

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054