



C-12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 503

Dated: 07/08/2024

To

The Head Of School, (School ID No- 1207264)
Govt. Lady Noyce Pry Special School (Co-ed)
at Nehru Vihar, Delhi-110084.

Sub: - Regarding issuance of fire safety certificate in r/o Govt. Lady Noyce Pry Special School (Co-ed) located at Nehru Vihar, Delhi-110054.

Sir,

Please refer to your letter received through online e-mail dated 12.07.2024 on the subject cited above. In this connection this is to inform you that the above mention site was visited by the officer concerned of this department on 26.07.2024 in the presence of Sh. Jaspal Singh (Guard) was also present at site to check the existing fire safety & means of escape measures. During inspection it has been observed that the education building is comprised of ground & 02 upper floors only. The observations/ shortcomings made are as under:-

1. First aid hose reel hose is not provided.
2. Terrace level fire pump capacity of 450lpm is not provided.
3. Terrace level fire fighting water tank capacity of 10,000ltr is not provided.
4. Exit signage and floor signage not provided at strategic locations in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the abovementioned shortcomings under intimation to this department; till such time running of building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.