

C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/School/SZ/2024/506

Dated 07/08/2024

To,

The Principal,
Govt. Sarvodaya Bal Vidyalaya No. 02,
Tilak Nagar, New Delhi- 110018.

Sub: - Regarding renewal of fire safety certificate in r/o Govt. Sarvodaya Bal Vidyalaya No. 02 located at Tilak Nagar, New Delhi- 110018.

Sir,

Please refer to your letter No. Nil, dated 02.07.2024, on the subject cited above. In this connection, it is to inform you that the above said school building was inspected by the officer concerned of this department from safety point of view on dated 24.05.2024 in the presence of Sh. S.K. Mittal (In-charge).

During the course of inspection found that the school building having 02 blocks, namely New Block comprised of ground plus three upper floors and Old Block is comprised of ground plus two upper floors (Old blk of ground floor demolished by PWD & Old blk ground plus one upper floor is declared unsafe. However, the following shortcomings have been observed: -

- 1 First Aid hose reels found provided but not functional.
- 2 Terrace Fire pump found provided but not functional in New Block and pump found removed in Old Block.
- 3 Exit signage's found removed.

Keeping in view of above, issuance of fire safety certificate cannot be considered at this stage. You are requested to rectify the above said shortcomings for taking further necessary action in this matter under intimation to this department.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

The Director of Education, GNCT of NCT of Delhi, Old Secretariat- 110054.