

C-2

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/School/508

Dated: 07/08/2024

To,

The Principal,
Ch. Rajendera Singh Memorial Educational
& Charitable Society
A-612 Street no -16 , Nala Road,
Mahavir Enclave-II,
New Delhi-110059

Subject: Issuance of Fire Safety Certificate in r/o Ch. Rajendera Singh Memorial Educational & Charitable Society Located at A-612 Street no -16 , Nala Road Mahavir Enclave-II, New Delhi-110059

Sir,

Please refer to letter no outdoor diary no-3282 dated- 24/06/2024 on the subject mentioned above. In this connection it is to inform you that the new block was inspected by the officer concerned from this department on 31/07/2024 in the presence of Mr. Dharendra Prakesh (Principal) from fire safety point of view.

During the course of inspection following shortcomings are observed.

1. The passage to 2nd stair found not clear.
2. Two ABC type Fire Extinguishers of 5kg capacity at each floor found not provided
3. Exit signage's found not provided.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054.