

C-78

DFA+FT
②

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/2024/WZ/ 502

Dated: 07/08/2024

To,

The Principal,
Rising Star Academy Sr. Sec. School,
110, Raj Nagar, Pitampura,
Delhi-110034.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Rising Star Academy Sr. Sec. School, located at 110, Raj Nagar, Pitampura, Delhi- 110034.

Sir,

This has reference to your letter No. RSA/2024/07/328 dated 20/07/2024 received via outdoor diary number 4418 dated 22/07/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 26.07.2024 to see the compliance of the requisite fire safety measures. Sh. Pradeep Kumar was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground and Three upper floors. Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. Terrace level pump not found in auto mode.
2. Exit signage's found removed at some places.
3. Temporary room found constructed under the staircase has to be removed.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully


(Atul Garg)
Director

Ph. 011-23414000

Copy to :-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.