



C-44

DPA
FT

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ SOS

Dated: 07/08/2024

To
Rev. Fr. Savariraj (Principal)
Rosary Senior Sec. School at
Radio Colony, Kingsway Camp, Delhi-09

Sub: - Regarding renewal of fire safety certificate in r/o Rosary Senior Secondary School at Radio Colony, Kingsway Camp, Delhi-110009.

Sir,

Please refer to your letter No. RS/2024-25/6880 dated 15.07.2024 received in this department vide outdoor dairy no.4170 dated: 15.07.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26.07.2024 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of 02 blocks, A- block comprised of ground plus 03 upper floors & B-block comprised of ground plus 02 upper floors. At the time of inspection Mr. Antony (Attendant) was also present at site. During the course of inspection the observations/ shortcomings made are as under:-

1. Hose reel hose is provided but not functional and short in no's.
2. Internal hydrant is provided but not functional & damaged condition. Some hoses, branch & coupling found missing.
3. Terrace level fire pump capacity of 450lpm each found not functional and badly damaged condition. Fire service inlet at ground level found damaged condition
4. Terrace level fire water tank capacity of 5000ltr each block found empty and is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.
5. Exit, floor & lift signages found removed at strategic locations in the school building.
6. Electrical panel below in staircase needs to be removed/shifted in a safer place.
7. Temporary tin shed constructed at A-block terrace for storage old furniture carpets & sofa seats is highly flammable ^{at} ~~needs to~~ be removed.
8. One staircase of both blocks from ground to terrace level found obstruct by combustible old damaged furniture material/ highly flammable & risk of life needs to be removed.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school building is at your own risk & responsibility.

Yours faithfully

(Atul Garg)
Director

Ph: 011-23414000

Copy to:-

1. The Dy. Director of Education/ PSB Director, Education (Private School Branch), Government of N.C.T of Delhi. Old Secretariat, Delhi - 110054.