



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-46
DFA
ET

No. F6/DFS/MS/2024/ CC/247

Dated: 08/08/2024

To

Sh. Rituraj Gupta
Plot No- 2514, Ground & First Floor,
Hudson Line, Delhi-110009.

Sub: - Regarding issuance of fire safety certificate in r/o Sardar Patel Computer Coaching Centre located at Plot No- 2514, Ground & First floor, Hudson Line, Kingsway Camp, Delhi-110009.

Sir,

Please refer to your letter no. Nil received in this department vide outdoor dairy no-3980 dated 09.07.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 26.07.2024 in the presence of Sh. Rituraj Gupta was also present at site to check the existing fire safety measures & means of escape measures. During inspection it has been observed that the building is comprised of basement, ground & 03 upper floors but (coaching centre running at ground & first only). The observations/ shortcomings made are as under:-

1. Only one staircase continues from ground to terrace level against the requirement of both staircase continues from ground to terrace level.
2. The width of classroom doors is 01m against the requirement of 1.20m.
3. Hose reel hose is not provided.
4. Terrace level fire pumps capacity 450lpm is not provided.
5. Terrace level fire water tank capacity 10, 000ltr is not provided.
6. Exit signage's is not provided at strategic location in the building.
7. Standby power supply is not provided.

You are requested to submit sanctioned building plan or as built plan duly signed by registered architect and owner of the above building and rectify above mentioned shortcomings under intimation to this department failing which action will be initiated as per Delhi fire Service Act 2007 & Rules 2010. Till the compliance of shortcomings coaching centre shall not be allowed to operate & management will be held responsible for any loss of life & property.

Yours faithfully

(Atul Garg)
Director

Ph:-011-23414000

Copy to:-

"For information & suitable action"

1. The Executive Engineer (Bldg.)-I, Rajpura Road, Civil Line Zone, Delhi.
2. The SHO, Police Station, Mukharjee Nagar Delhi-110009.