



Dated: 07/08/2024

No. F6/DFS/MS/School/NDZ/2024/511

To,

Mrs. Asha Joyti (Principal),
Sarvodaya Kanya Vidyalaya,
Vivek Vihar,
Delhi – 110095.

Subject: - Regarding grant of Fire Safety Certificate in r/o Sarvodaya Kanya Vidyalaya located at Vivek Vihar, Delhi – 110095.

Sir,

This has a reference to your Email dated 22/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 26/07/2024 in the presence of Mrs. Asha Joyti (Principal) & Mr. Jitender Prakash (Estate Manager), and observed that building comprised of ground plus three upper floors (New Building) & ground plus one upper floor (Old Building).

Following shortcomings were observed during time of inspection:

1. All Fire Extinguishers found empty.
2. First-Aid-Hose Reel provided but not functional.
3. Fire pump of 450 LPM provided but not functional
4. Exit signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.