

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/NDZ/2024/ 440

Dated: 07/08/2024

To,
The Executive Engineer (Bldg) HQ -II,
Building Department,
NDMC, 8th floor, Civic Centre, Minto Road,
New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o T1& T2 tower (business) at10196, Keshav Kunj, Jhandewalan, New Delhi.

Sir,

This has a reference to online Id no. 10074722 dated 01/08/24, on the subject cited above. In this connection, it is to inform you that the Tower 1&2 was inspected by the officers concerned of this department on 01/08/24 in the presence of, Sh. Shekhar Singh JE, MCD and observed ~~that~~ the following shortcomings :

1. 09 meter all around road is not available at one place at back side of building.
2. Fire checks doors are not provided on the staircases serving to basement
3. Electrical shafts/ openings are not sealed at floor level properly.
4. Smoke management system is not integrated with detection system in basement.
5. Detectors and sprinklers are not provided in some offices and auditorium also.
6. Exit & lifts signage's are not provided.
7. The civil & firefighting works in auditorium is also not completed.

In view of above case is rejected with a request to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully


(Atul Garg)
DIRECTOR

Delhi Fire Service

26/8/24
3/8