



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hotel/2024/SZ/ 30

Dated: 06/08/2024

To

Sh. P. K. Biswal (DGM-E&M),
M/s The Ashok Hotel,
50-B, Diplomatic Enclave,
Chanakya Puri, New Delhi-110021

Sub: Regarding renewal of Fire Safety Certificate of "The Ashok Hotel" located at 50-B, Chanakyapuri, New Delhi-110021

Sir,

This has reference to your letter No. AH/Engg/E&M/Inspection/24 dated 10/07/2024 received through outdoor diary No. 4093 dated 11/07/2024. In this connection, inspection from fire & escape safety point of view was conducted by the officers concerned of this department on dated 02/08/2024 in your presence and Sh. Sh. Satish Kumar (Asst. Manager). During the course of inspection, the shortcomings observed are as below.

1. Fire Check Door found removed at some places.
2. Single exit provided in "The Coffee Shop" against required two exits.
3. Hose-reel hose at terrace found removed.
4. Electrical shaft not sealed properly at some places.
5. MOEFA/MCPs found under repair/replacement.
6. Public Address system need to be extended in presidential suites.
7. Sprinklers found removed in Friendship Lounge & Banquet Hall.
8. Over-head storage tank found removed.
9. Exit signages found removed at some places.
10. Lift signages found removed at some places.
11. Second exit of service lift at 7th floor found closed/sealed.
12. Luggage lift was under repair/replacement.
13. Ordinary doors provided in lift lobby at 3rd floor shall be replaced with fire/smoke door.
14. Loose wires hanging at a height less than 6 feet are dangerous & safety hazards.

In view of the shortcomings above, the application for renewal of fire safety certificate is rejected. The occupancy of the building/premises in the absence of requisite fire safety arrangements shall be at the risk and responsibility of the owner/occupier. The licensing/local authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station Defence Colony, New Delhi-110049
2. The Executive Engineer (Bldg.), N.D.M.C, Palika Kendra, New Delhi-110001