

C-24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2024/SZ/516

Dated: 09/08/2024

To

The Principal,
Sanatan Dharam Vidya Bhavan,
R-4, Raghunath Mandir, Alaknanda,
Kalkaji, New Delhi 110019

Sub: Regarding issuance of FSC in r/o M/s Sanatan Dharam Vidya Bhavan, at R-4, Raghunath Mandir, Alaknanda, Kalkaji, New Delhi 110019.

Sir,

This has reference to letter received through Email dated 04-06-2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 05.08.2024 in the presence of Mrs. Usha Vasudevan (Principal) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but found non-functional.
2. Internal hydrant provided but found non-functional.
3. Terrace level Fire Pump capacity of 450 LPM provided but found non-functional.
4. Exit signage found removed in some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54