

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/Motel/2024/SZ/ 438

Dated: 05/08/2024

To
The Joint Commissioner of Police,
Lic/Unit 1st Floor PS Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of Fire Safety Certificate in r/o Motel Building, (Nitesh Kunj A unit of Delhi Apartments Pvt Ltd) at Khasra No 33.1.10.2 NH-8, Village, New Delhi

Sir,
This has reference to with **MHA Portal ID 2024070610549 & 2024070610525 dated 06/07/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 01.08.2024 in the presence of Mr. Anjani to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The Fire check door found removed at some places.
2. The First Aid Hose reel provided but found non-functional.
3. Automatic detection and alarming system provided but found non functional.
4. Automatic sprinkler system provided but found non-functional.
5. The Internal provided but found non-functional.
6. Fire fighting pumps are not on auto mode.
7. Exit signage's found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE