



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/23

7/2
आप्लादीय
अमृत महोत्सव

No. F6/DFS/MS/EH/NDZ/2024/ 315

Dated: 02/08/2024

To,

The Manager,
Sagar Ratan Restaurants Pvt. Ltd.,
G-86, (GF & FF),
Preet Vihar, Vikas Marg,
Delhi - 110092.

**Sub: - Regarding grant of Fire Safety Certificate in r/o Sagar Ratan Restaurants Pvt. Ltd.
located at G-86, (GF & FF), Preet Vihar, Vikas Marg, Delhi - 110092.**

Sir,

This has a reference to your MHA portal application No. 2024070510456 dated 05/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 21/07/2024 in the presence of Mr. Gaurav Pandey (Manager) and observed that building comprised of basement, ground plus three upper floors only, (Restaurant is running at ground and first floor only).

Following shortcomings were observed during time of inspection:

1. All Fire Extinguishers found empty.
2. First-Aid-Hose Reel provided but not functional.
3. Automatic sprinkler system provided but not functional.
4. Internal hydrants provided but not functional.
5. Pump provided but not functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

ok (w) DELHI FIRE SERVICE

Copy to: -

1. The Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24
w.e.f. - MHA portal ID - 2024070510456 dated 05/07/2024