



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

0175  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/GH/SZ/2024/ 464

Dated: 05/08/2024

To

The Joint Commissioner of Police (Licensing),  
1st Floor, Police Station,  
Defence Colony, New Delhi.

**Sub:-** Regarding grant of Fire Safety Certificate in r/o M/s Ashu Villa Guest House located at  
**149/3, Kilokri Opposite Maharani Bagh, New Delhi-14.**

Sir,

With reference to the online application no. 2024061809511 on the subject cited above, it is informed that the building was inspected by Assistant Divisional Officer (M. Road) from this department on 29.07.2024 in the presence of Mr. Ashu (Owner) and it was observed that the building is comprised of Ground + 4 upper floors. During the inspection following shortcomings were observed:-

1. Hose reels found non functional.
2. Fire pumps found non functional.
3. Ext sinages fount not provided.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Ajul Garg)

Director  
Delhi Fire Service

29/7/24 N