

C/41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2024/SZ/ 550

Dated: 20/08/2024

To,
The Manager,
Blooming Tree School,
C-2 Block, Janakpuri, New Delhi-110058.

Sub: -Regarding renewal of "Fire Safety Certificate" from fire safety point of view in r/o Blooming Tree School at C-2 Block, Janakpuri, New Delhi-110058.

Sir,
Please refer to your letter No. Nil, dated Nil received through office outdoor dairy No. 2321 dated 03.06.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 02.08.2024 in the presence of Manager, to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the school building comprised of basement, ground floor plus two upper floors & Barsati on terrace (not in use), and have following shortcomings: -

1. A stage constructed in the basement should be removed.
2. Hose reel found provided but not functional.
3. Terrace fire pump 450 LPM × 2 found provided but not functional in auto mode.
4. Exit signage's are found removed.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

2. The Executive Engineer (E), Municipal Corporation of Delhi, 9th Floor, Civic Centre, Minto Road, New Delhi- 110002

: - for necessary action please.
: - for information regarding use of basement.