



C-43

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/BNQT/NDZ/2024/ 340

Dated: 16/08/2024

To,

The Joint Commissioner of Police (Lic.),
1st Floor, P. S. Defence Colony,
New Delhi-110024.

Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Good Fellows Hospitality LLP located at Metro Pillar No. 56, Ground floor, Adjoining Jhilmil Metro Station, Delhi – 110095.

Sir,

This has a reference to MHA Portal application No. 2024071611107 dated 16/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 08/08/2024 in the presence of Mr. Raj Arora (Owner) and observed that the building is constructed as pandal (Temp. structure) and comprised of ground floor only.

Following shortcomings were observed during time of inspection:

1. The width of two doors size is 2.0 & 1.60 meter against the requirement of 2.0 meter each.
2. Fire check door not provided.
3. First-Aid-Hose Reel provided but not functional.
4. MOEFA system not provided.
5. Public address System not provided.
6. Internal Hydrant not provided.
7. Fire pump of 900 LPM provided but not functional.
8. Overhead water storage tank capacity 15,000 liters is provided against requirement of 25,000 liters.
9. Exit & floors Signage's not provided at strategic location in the building.
10. Certificate regarding non-combustible material used for construction shall be provided.
11. Fire-fighting system shall be integrated with the system provided in Jhilmil Metro Station.

In view of above shortcomings, the application for issuance for Fire Safety Certificate at this stage is rejected.

Yours faithfully,


(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. Mr. Raj Arora (Owner), M/s Good Fellows Hospitality LLP located at Metro Pillar No. 56, Ground floor, Adjoining Jhilmil Metro Station, Delhi – 110095.