

C-55

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI- 110001**

No. F6/DFS/MS/Banquet/2024/SZ/ 97

Dated: 14/08/2024

To,

The Joint C.P. (Lic.),  
1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.

**Sub: - Regarding renewal of FSC from fire safety point of view in r/o M/s Green Lounge Premium Banquets at C-97, GF & FF, Mayapuri Industrial Area, Phase-II, New Delhi-110064.**

Sir,

Please refer to online application ID 2024071511007 dated 15.07.2024, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the banquet hall building on dated 09.08.2024 in the presence of Sh. Bablu Kumar (Caretaker), to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the banquet hall running at ground and first floor only of a building comprised of basement, ground plus three upper floors, and have following shortcomings were observed: -

1. Gate of banquet hall found closed by lock from outside and blocked by sofa set at ground floor and first floor from inside.
2. Smoke management system found non-functional in banquet hall.
3. Hose reels/hydrant system found provided but not functional.
4. Both Pumps are found not functional.
5. Water storage tank of 5,000 ltrs found provided instead of 20,000 ltrs.
6. Exit signage's are found removed at banquet hall area.
7. Submitted drawing is not matching with actual profile of the building.

In view of above, renewal of fire safety certificate cannot be considered at this stage. Therefore, you are suggested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running banquet hall in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The owner/occupier, M/s Green Lounge Premium Banquets at C-97, GF & FF, Mayapuri Industrial Area, Phase-II, New Delhi-110064.