



No. F6 /DFS/MS/College/SZ/2024/ 455

Dated: 16/08/2024

To

The Owner/Occupier/Manager,
M/s Institute of Hotel Management & Catering Technology,
Lajpat Nagar-IV, New Delhi.

Sub: - Regarding issuance of Fire Safety Certificate in r/o **M/s Institute of Hotel Management & Catering Technology** located at **Lajpat Nagar-IV, New Delhi.**

Sir,

With reference to the your letter bearing outdoor diary no. 3519 dated 27.06.2024 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned of this department on 01.08.2024 in the presence of Sh. Balkishan Shishodia (Section Officer) and it was observed that the building is comprised of Ground + 03 upper floors. During the inspection following shortcomings were observed:

1. Two staircases of 1.50 meters width each shall be provided.
2. MP Hall exceeding 390 m² shall have 2 exit doors of 2.0 meters width each and each kitchen used for training purposes shall have minimum 2 exits.
3. Hose reel found non functional.
4. Terrace Fire pump found non functional.
5. Lift & exit sinages found not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

08/08/24 N

Copy to:-

1. The Executive Engineer (Building), South DMC, Jal Vihar, Lajpat Nagar, New Delhi-24.