



No. F6/DFS/MS/Hospital/NDZ/2024/ 456

Dated: 16/08/2024

To,

The Authorized Signatory,
Executive Engineer, HPD (East),
PWDR.G.S.S, Hospital Tahirpur,
Delhi – 110093.

Subject: - Regarding grant of Fire Safety Certificate in r/o Lal Bahadur Shastri Hospital, located at Khichripur, Delhi – 110092.

Sir,

This has a reference to your outdoor diary no. 4334 dated 19/07/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 07/08/2024 in the presence of Mr. Sunit Dutt PWD (A/E) and observed that building comprised of ground plus four upper floors.

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel provided but not functional.
2. Automatic Fire Detection and Alarming System but not functional.
3. MOEFA provided but not functional.
4. Public Address System provided but not functional.
5. Internal Hydrants provided but not functional.
6. Pumping arrangements one electric pump of 1620 LPM, one jockey pump of 180 LPM and one diesel pump of 1620 LPM fire pump provided but not functional.
7. Exit & floors Signage's not provided at strategic location in the building.
8. Detector system panels, Flow switch panel, PA system panel, Battery backup were not functional at the time of inspection.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

O/C

Copy to: -

1. The Executive Engineer (Bldg), Municipal Corporation of Delhi, Plot no. 419, Patparganj Industrial Area, Delhi -110092.
2. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3rd floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi – 110032.