



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-28



No: F.6/DFS/MS/School/2024/WZ/ 545

Dated: 20/08/2024

To,

The Principal,
Mahavira International School,
1149, Deva Ram Park,
Tri Nagar, Delhi-110035.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Mahavira International School located at 1149, Deva Ram Park, Tri Nagar, Delhi- 110035.

Sir,

This has reference to your letter no. Nil received through outdoor diary no. 4620 dated 26.07.2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 09.08.2024 to see the compliance of the requisite fire safety measures. Smt. Shalini Jain was present at the time of inspection.

During the course of inspection it was observed that the school is running on Ground and three upper floors in a building comprised of Basement, Ground plus four upper floors. Fire safety systems such as First aid hose reels, terrace level pump found provided and functional in the building. Your request for issuance of FSC is rejected as the following shortcomings were observed:-

1. Width of staircases found 1.10 m & 0.83 m against the required width of 1.50 m each.
2. Fire check door not provided in basement.
3. There is only one staircase reaches up to terrace against the requirement of two staircases up to terrace.
4. Width of corridor found 0.90 m against the required width of 1.50 m.
5. Building plan on a scale of 1:100 from a registered architect not provided.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

14/8

Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.
2. The Executive Engineer Building, MCD, Keshavpuram Zone, Keshavpuram, Delhi-110035.